

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

To,

SDKL DAV CENT.SENIOR SECONDARY PUBLIC SCHOOL
MANSA


No.: DWTL/MNS/2627/00126 Dated : 05/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 254/DAV/MANSA/2026 Dated: 30/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 30/04/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Mansa



TEST REPORT

Name & Address of Customer : SDKL DAV CENT.SENIOR SECONDARY PUBLIC SCHOOL MANSA		Customer Reference No.	No : 254/DAV/MANSA/2026 Dated : 30/04/2026			
		Sample Submitted by	MR BALRAJ CHAUDHARY			
		Date of Sample Receipt	30/04/2026			
		Analysis Starting Date	04/05/2026			
		Analysis completion Date	05/05/2026			
Discipline :		Group: Water				
ULR No.:	TC11386260000201F	Sample Type :	Water			
Test Report No.:	DWTL/MNS/2627/00126	Date of Issue :	05/05/2026			
Registration no.:	DWTL/MNS/REG2627/00213	Condition of Sample :	Unsealed			
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle			
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	SDKL DAV CENT.SENIOR SECONDARY PUBLIC SCHOOL / NA			
Village :	Not Mentioned	Habitation :	Not Mentioned			
Block:	Not Mentioned	District :	Mansa			
Latitude :	Not Mentioned	Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.09@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	NT	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	260	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	122	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	204	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	56.91	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	15.06	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	26.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Mansa

----- End of the Test Report -----